

**ANNUAL DRINKING WATER QUALITY REPORT FOR 2016**  
**CITY OF FRUITLAND**  
**PWSID # 0220008**  
**APRIL, 2017**

We're pleased to present to you this year's Annual Water Quality Report. This report is designed to inform you about the water quality and services we deliver to you every day. Our constant goal is to provide you with a safe and dependable supply of drinking water. We want you to understand the efforts we make to continually improve the water treatment process and protect our water resources. We are committed to ensuring the quality of your water. Our water source is four wells located at the water plant which are drilled approximately 85 feet into the Columbia aquifer.

An updated source water protection plan prepared by the Maryland Department of the Environment provides more information such as potential sources of contamination. This plan is dated February 2000 and is available for review at City Hall.

We are pleased to report that our drinking water is safe and meets federal and state requirements.

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by cryptosporidium and other microbiological contaminants are available from the Safe Drinking Water Hotline (800-426-4791).

If you have any questions about this report or concerning your water utility, please contact **Mike Gibbons at (410) 548-2800, P.O. Box F, Fruitland, MD 21826**. We want our valued customers to be informed about their water utility. If you want to learn more, please attend any of our regularly scheduled meetings. They are held on **the 2<sup>nd</sup> Tuesday of every month at 7:30 p.m. at City Hall, 401 East Main Street**.

The **City of Fruitland** routinely monitors for contaminants in your drinking water according to Federal and State laws. This table shows the results of our monitoring for the period of January 1<sup>st</sup> to December 31<sup>st</sup>, 2016. As water travels over the land or underground, it can pick up substances or contaminants such as microbes, inorganic and organic chemicals, and radioactive substances. All drinking water, including bottled drinking water, may be reasonably expected to contain at least small amounts of some contaminants. It's important to remember that the presence of these contaminants does not necessarily pose a health risk.

In this table you will find many terms and abbreviations you might not be familiar with. To help you better understand these terms we've provided the following definitions:

*Parts per million (ppm) or Milligrams per liter (mg/l)* - one part per million corresponds to one minute in two years or a single penny in \$10,000.

*Parts per billion (ppb) or Micrograms per liter* - one part per billion corresponds to one minute in 2,000 years, or a single penny in \$10,000,000.

*Maximum Contaminant Level* - The “Maximum Allowed” (MCL) is the highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

*Maximum Contaminant Level Goal* - The “Goal” (MCLG) is the level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

<b>TEST RESULTS</b>						
Contaminant	Violation Y/N	Level Detected	Unit Measurement	MCLG	MCL	Likely Source of Contamination
<b>Inorganic Contaminants</b>						
Copper (Distribution) (2016)	N	0.18	ppm	1.3	AL=1.3	Corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives
Nitrate (as Nitrogen) (2014) Range Average	N	2.8–4.7 5	ppm	10	10	Runoff from fertilizer use; leaching from septic tanks, sewage; erosion of natural deposits
Lead (Distribution) (2016)	N	ND	ppb	0	AL=15	Corrosion of household plumbing systems, erosion of natural deposits
Chlorine (2016)	N	0.9	ppm	4	4	Water Additive used to control microbes
Fluoride (2014)	N	0.6	ppm	4	4	Erosion of natural deposits; water additive which promotes strong teeth; discharge from fertilizer and aluminum factories
<b>Radioactive Contaminants</b>						
Beta/photon emitters (2014)	N	4.6	pCi/l	0	50	Decay of natural and man-made deposits
<b>Volatile Organic Contaminants</b>						
TTHM (Distribution) (2016) [Total trihalomethanes]	N	12	ppb	0	80	By-product of drinking water chlorination
Haloacetic Acids (HAA5s) (Distribution) (2015)	N	3	ppb	0	60	By-product of drinking water chlorination
<b>Unregulated Contaminants</b>						
Sodium (average) (2014)	N	35.8	ppm	N/A	N/A	Erosion of natural deposits
pH, range (2014)	N	7.3				
cis-1,2-dichloroethylene (2012)	N	1.5	ppb	70	70	Discharge from industrial chemical factories
Methyl Tert Butyl Ether (2012)	N	0.7	ppb	N/A	N/A	Possible Fuel Leak

*Note: Test results are for year 2016 unless otherwise noted. All contaminants do not require annual testing.*

As you can see by the table, our system had no violations. We're proud that your drinking water meets or exceeds all Federal and State requirements. We have learned through our monitoring and testing that some contaminants have been detected. The EPA has determined that your water IS SAFE at these levels.

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. The City of Fruitland is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your drinking water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the EPA Safe Drinking Water Hotline at 1-800-426-4791 or at <http://www.epa.gov/safewater/lead>.

**NOTE: As can be seen by results listed in the above tables, lead, which is tested for on a triennial basis (every 3 years) in Fruitland in accordance with Federal and State regulations, has not been detected in collected samples. Our most recent testing was in 2016.**

All sources of drinking water are subject to potential contamination by substances that are naturally occurring or man made. These substances can be microbes, inorganic or organic chemicals and radioactive substances. All drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline at 1-800-426-4791.

MCLs are set at very stringent levels. To understand the possible health effects described for many regulated contaminants, a person would have to drink 2 liters of water every day at the MCL level for a lifetime to have a one-in-a-million chance of having the described health effect.

This annual water quality report (CCR) is required to be completed and posted for our residents by July 1<sup>st</sup> of each year. A copy must also be sent to Maryland Department of the Environment (MDE) by that date.

In our continuing efforts to maintain a safe and dependable water supply it may be necessary to make improvements in your water system. The costs of these improvements may be reflected in the rate structure. Rate adjustments may be necessary in order to address these improvements.

Please call our office if you have questions.

We at the City of Fruitland work around the clock to provide top quality water to every tap. We ask that all our customers help us protect our water sources, which are the heart of our community, our way of life and our children's future.